

# Annexure C

Appendix - XIII

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 226

Dated: 31-05-2023

It is certified that an inspection team headed by Vijayant Kumar  
(Name of Officers with designation) from Sanitary Inspector Nagar Palika Parishad  
(Name of Department/Office) inspected the Little Angel School Kichha Kichha  
(Name & Address of the school) on 27.5.23 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

The above is valid for a period of one year

Signature with seal:

Name :

Designation :

Name & Address of the Office / Department :

अधिसारी अधिकारी  
नगर पालिका परिषद किच्हा

(कृष्ण सिंह नगर)

Gurmeet Singh

Executive officer

Nagar Palika Parishad  
Kichha

To

Principal

Little Angel School Kichha

(Name & Address of the Institution)

- The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



**District Level Water Quality Testing and Monitoring Laboratory  
Uttarakhand Jal Sansthan, Rudrapur U.S.Nagar**

E-mail: [eeudmujs@gmail.com](mailto:eeudmujs@gmail.com)


Test Report ID: 61/UJS/DLWQTML/2023-24


**WATER QUALITY TEST REPORT**

Name and Address of Organization/ Customer	Little Angel School Nearv Raj Petrol Pump Kiccha (U.S.Nagar)		
Type of Source (Drinking Water/ Ground Water/ Sub-Surface Water)	Sample Description: Drinking Water	One water Sample Collect from RO	
Reference Sample Identification:	DLWQTML/UJS/LAS-01	Date of Start of Analysis: 26.05.2023 Date of End of Analysis : 27.05.2023	
Date of Sample Received: 26.05.2023	Sample Collected by:	Customer	

S.No.	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS)
1	Colour	Less than 1	5	15
2	Odour	Unobjectionable	Unobjectionable	Unobjectionable
3	Taste	Agreeable	Agreeable	Agreeable
4	Total Dissolved Solids (TDS), mg/l max	80	500	2000
5	pH at 25°C	7.41	6.5 to 8.5	No Relaxation
6	Turbidity, NTU ma	0.40	1	5
7	Chloride, Mg/l max	4.99	250	1000
8	Total Alkalinity as CaCO <sub>3</sub> mg/l max	57	200	600
9	Total Hardness as CaCO <sub>3</sub> mg/l max	64	200	600
10	Calcium as Ca mg/l max	20.0	75	200
11	Magnesium as Mg mg/l max	3.40	30	100
<b>Microbiological Test Parameters</b>				
12	E.Coli MPN /100ml	Absent	Absent	Absent
13	Total Coliform/100ml	Absent	Absent	Absent

**Remark:** Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

  
Chemist

  
Lab Incharge/Quality Manager  
Technical Manager  
District Water Quality Testing  
Monitoring Laboratory  
Uttarakhand Jal Sansthan, U.S.Nagar

-End of Report -